

PERMITTEE NAME/ADDRESS:

NAME: ANCHORAGE, MUNICIPALITY OF
ADDRESS: 3000 ARCTIC BLVD.
ANCHORAGE AK 99503-3898

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

AK0022551	001 A
PERMIT NUMBER	DISCHARGE NUMBER

Form Approved
OMB No. 2040-0004

MAJOR
(SUBR 02)
F - FINAL

FACILITY: JOHN M. ASPLUND WWTF---301 (H)
LOCATION: ANCHORAGE, AK 99502
ATTN: MARK PREMO P.E. GEN MGR. AWWU

MONITORING PERIOD

FROM 05 | 11 | 01 TO 05 | 11 | 30

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNIT			
TEMPERATURE, WATER DEG. CENTIGRADE 00010 G 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	13.8	(04)	N/A	FOUR/WEEK	GRAB
RAW SEW/INFLUENT	PERMIT REQUIREMENT	*****	*****	****	*****	*****	REPORT MAXIMUM	DEG.C		FOUR/WEEK	GRAB
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	*****	*****	13.7	(04)	N/A	FOUR/WEEK	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	*****	REPORT MAXIMUM	DEG.C		FOUR/WEEK	GRAB
OXYGEN, DISSOLVED (DO) 00300 1 0 0	SAMPLE MEASUREMENT	*****	*****	****	2.6	*****	*****	(19)	N/A	FOUR/WEEK	GRAB
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	REPORT MO MIN	*****	*****	MG/L		FOUR/WEEK	GRAB
BOD, 5-DAY (20 DEG. C) 00310 G 0 0	SAMPLE MEASUREMENT	45649	*****	(26)	*****	206	*****	(19)	N/A	FOUR/WEEK ¹⁾	COMP24
RAW SEW/INFLUENT	PERMIT REQUIREMENT	REPORT MO AVG	*****	LBS/DY	*****	REPORT MO AVG	*****	MG/L		FOUR/WEEK	COMP 24
BOD, 5-DAY (20 DEG. C) 00310 W 0 0	SAMPLE MEASUREMENT	*****	34208	(26)	*****	*****	151	(19)	0	FOUR/WEEK ¹⁾	COMP24
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	90100 DAILY MX	LBS/DY	*****	*****	300 DAILY MX	MG/L		FOUR/WEEK	COMP 24
BOD, 5-DAY (20 DEG. C) 00310 1 0 0	SAMPLE MEASUREMENT	29750	32254	(26)	*****	135	142	(19)	0	FOUR/WEEK ¹⁾	COMP24
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	72100 MO AVG	75100 WKLY AVG	LBS/DY	*****	240 MO AVG	250 WKLY AVG	MG/L		FOUR/WEEK	COMP 24
PH 00400 G 0 0	SAMPLE MEASUREMENT	*****	*****	****	7.1	*****	7.8	(12)	N/A	FOUR/WEEK	GRAB
RAW SEW/INFLUENT	PERMIT REQUIREMENT	*****	*****	****	REPORT MINIMUM	*****	REPORT MAXIMUM	SU		FOUR/WEEK	GRAB

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN, AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §1001 AND 33 U.S.C. §1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)

M. Spano for Kris Warren

TELEPHONE

DATE

J. Kris Warren
Manager, Treatment Division

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

(907)564-2799

05/12/08

TYPED OR PRINTED

AREA CODE NUMBER

YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Forms by WindowChem(707)864-0845;p/n11090;v5.01;4/1/96. Rev. 1/05, B

1) Influent and effluent BOD tests for 11/21 & 22/05 & influent BOD test for 11/26/05 were run, but results were invalid due to lab error.

ms 12/29/05

NAME: ANCHORAGE, MUNICIPALITY OF
ADDRESS: 3000 ARCTIC BLVD.
ANCHORAGE AK 99503

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Form Approved
OMB No. 2040-0004

DISCHARGE MONITORING REPORT (DMR)

AK0022551	001 A
PERMIT NUMBER	DISCHARGE NUMBER

MAJOR
(SUBR 02)
F - FINAL

FACILITY: JOHN M. ASPLUND WWTF---301 (H)
LOCATION: ANCHORAGE, AK 99502
ATTN: MARK PREMO P.E. GEN MGR. AWWU

MONITORING PERIOD

FROM	05	11	01	TO	05	11	30
------	----	----	----	----	----	----	----

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNIT			
PH	SAMPLE MEASUREMENT	*****	*****	****	6.9	*****	7.3	(12)	0	FOUR/WEEK	GRAB
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	6.5 MINIMUM	*****	8.5 MAXIMUM	SU		FOUR/WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	46187	*****	(26)	*****	209	*****	(19)	N/A	FOUR/WEEK	COMP24
00530 G 0 0 RAW SEW/INFLUENT	PERMIT REQUIREMENT	REPORT MO AVG	*****	LBS/DAY	*****	REPORT MO AVG	*****	MG/L		FOUR/WEEK	COMP24
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	15054	(26)	*****	*****	74	(19)	0	FOUR/WEEK	COMP24
00530 W 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	57000 DAILY MX	LBS/DAY	*****	*****	190 DAILY MX	MG/L		FOUR/WEEK	COMP24
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	11235	12002	(26)	*****	51	57	(19)	0	FOUR/WEEK	COMP24
00530 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	51000 MO AVG	54000 WKLY AVG	LBS/DAY	*****	170 MO AVG	180 WKLY AVG	MG/L		FOUR/WEEK	COMP24
NITROGEN, AMMONIA TOTAL (AS N)	SAMPLE MEASUREMENT	*****	*****	****	*****	20.8	*****	(19)	N/A	ONCE/MONTH	COMP24
00610 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	REPORT MO AVG	*****	MG/L	N/A	ONCE/MONTH	COMP24
FECAL COLIFORM, MPN, EC MED, 44.5C	SAMPLE MEASUREMENT	*****	*****	****	*****	27	*****	(30)	0	THREE/WEEK ¹⁾	GRAB
31615 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	*****	850 MO GEO	*****	MPN/ 100ML		THREE/WEEK	GRAB
FLOW IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	26.979		(03)	*****	*****	*****	****	N/A	CONTINUOUS	RCORDR
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	MO AVG		MGD	*****	*****	*****	****		CONTINUOUS	RCORDR

J. Kris Warren

Manager, Treatment Division

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY OBTAINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY KNOWLEDGE OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §1001, AND 35 U.S.C. §1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE _____

(907)564-2799

05/12/08

AREA CODE NUMBER

YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Forms by WindowChem(707)864-0845;p/n11090;v5.01;4/1/96. Rev. 1/05. B

1) Two tests for week of 11/1/05 were invalid due to lab error. Four extra FC tests were run later in month.

NAME: ANCHORAGE, MUNICIPALITY OF
ADDRESS: 3000 ARCTIC BLVD.
ANCHORAGE AK 99503

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

Form Approved
OMB No. 2040-0004

DISCHARGE MONITORING REPORT (DMR)

AK0022551
PERMIT NUMBER

001 A
DISCHARGE NUMBER

MAJOR
(SUBR 02)
F - FINAL

FACILITY: JOHN M. ASPLUND WWTF---301 (H)
LOCATION: ANCHORAGE, AK 99502
ATTN: MARK PREMO P.E. GEN MGR. AWWU

MONITORING PERIOD

FROM	05	11	01	TO	05	11	30
------	----	----	----	----	----	----	----

*** NO DISCHARGE ☐ ***

NOTE: Read instructions before completing this form.

[illegible]

NAME / TITLE PRINCIPAL EXECUTIVE OFFICER

J. Kris Warren

Manager, Treatment Division

TYPED OR PRINTED

I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN; AND BASED ON MY KNOWLEDGE OF THE INFORMATION, I AM IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. §1601 AND 33 U.S.C. §1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years.)

SIGNATURE OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

TELEPHONE

DATE _____

(907)564-2799

05/12/08

AREA CODE NUMBER

YEAR MO DAY

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)	
--	--

1) 11/27/05 - one required chlorine test was missed. Permit requires test every 4 hours; there was a gap of 5.75 hours between tests. Whole Effluent Toxicity Test Report enclosed.

Forms by WindowChem(707)864-0845;p/n11090:v5 01-4/1/96, Rev. 1/05, B1